


TYPICAL INSIDE INSTALLATION
(2", 2 1/2", 3", 4", 6", 8", & 10" SIZES)

MATERIALS		
ITEM	QUAN.	DESCRIPTION
1	1	REDUCED PRESSURE ZONE DEVICE
2	2	OS&Y RESILIENT GATE VALVES
3	3	TEST COCKS
4	2	FLANGE ADAPTERS (3" AND LARGER) OR UNIONS (2" AND 2 1/2")
5		DUCTILE IRON PIPE, CUT TO FIT
6	1	AIR GAP DRAIN
7	1	FLOOR DRAIN SIZED PER MANUFACTURER RECOMMENDATION
8		DUCTILE IRON PIPE, CUT TO FIT

REDUCED PRESSURE DETECTOR ASSEMBLY
FOR INSIDE FIRE SYSTEM

STANDARD
CONSTRUCTION
DETAILS



CITY OF
savannah
WATER RESOURCES AND PUBLIC WORKS BUREAU
Planning & Engineering

SCALE: N.T.S.

DATED: SEP 2013

PLATE NUMBER:

W22